

## **AB 2282 Stakeholders Group**

### **California Water Service Additional Comments - CPC Express Terms, Proposed Amendments**

Concerns with the proposed changes to Section 1501.1.11.2.2 Cross-Connection Test:

- 1) Subsection 5 proposes a temporary connection between the potable water supply and the recycled water system. Title 17 defines this as a cross-connection. For the initial test only, and prior to connection of the internal recycled water piping to the recycled water distribution system, a temporary connection to the potable system should only be allowed through an approved RP, perhaps reference 1502.3.

Following the test, all connections for the bypass arrangement must be removed or sealed. If a means to connect the two systems is left in place, it may eventually be used, causing contamination of the potable water supply.

- 2) Denote the necessity of a having a “User Supervisor” or qualified individual attend the cross connection test.

Sample text: “A person with extensive knowledge of the internal plumbing systems at the site subject to a cross connection test or a designated User Supervisor as defined by section 7586 of Title 17 of the California Code of Regulations shall be in attendance to assist during testing.”